

Tabled Paper - LA QON 354 - Outages

Incident Reference	Localities impacted	Cause of interruption	Interruption start	Initial restoration	Final restoration
INCD-249791-U	Eneabba	Unknown	1/11/2021 10:19	1h 44m	1h 44m
INCD-252561-U	Mullewa	Unknown	2/11/2021 13:31	5h 43m	5h 43m
INCD-253211-U	Mullewa	Customer Installation or Appliance	2/11/2021 19:45	14h 50m	14h 50m
INCD-256281-U	Dongara	Emergency Outage For Hazard	4/11/2021 11:03	44m	44m
INCD-257841-U	Jurien Bay	Emergency Outage For Hazard	5/11/2021 8:02	1h 23m	1h 29m
INCD-264841-U	Eneabba	Unknown	9/11/2021 7:43	4h 23m	4h 23m
INCD-266751-U	Yuna	Equipment Failure (OH Switch Gear)	9/11/2021 14:10	3h 42m	3h 42m
INCD-272381-U	Northampton	Unknown	12/11/2021 8:59	2h 5m	7h 49m
INCD-276631-U	Mullewa	Unknown	14/11/2021 13:38	2h 7m	2h 7m
INCD-277481-U	Perenjori	Equipment Failure (OH Conductor)	15/11/2021 4:41	6h 34m	6h 35m
INCD-277901-U	Mullewa	Emergency Outage For Hazard	15/11/2021 9:05	4h 16m	4h 16m
INCD-280461-U	Jurien Bay	Emergency Outage For Hazard	16/11/2021 11:22	29m	29m
INCD-284671-U	Mullewa	Emergency Outage For Hazard	18/11/2021 9:43	4m	3h 41m
INCD-289751-U	Perenjori, Morawa	Unknown	21/11/2021 13:23	3h 42m	4h 6m
INCD-295941-U	Northampton, Yuna	Unknown	24/11/2021 7:44	35m	35m
INCD-296641-U	Mullewa	Unknown	24/11/2021 11:10	44m	45m
INCD-297271-U	Morawa	Emergency Outage For Hazard	24/11/2021 13:55	50m	50m
INCD-299871-U	Jurien Bay	Unknown	25/11/2021 14:29	1h 35m	1h 35m
INCD-304611-U	Gregory	Unknown	28/11/2021 8:18	6h 9m	6h 9m
INCD-305881-U	Yuna	Unknown	29/11/2021 5:13	32m	32m
INCD-305851-U	Nabawa	Equipment Failure (Pole Top Fire)	29/11/2021 10:01	1h 48m	2h
INCD-306741-U	Morawa	Emergency Outage For Hazard	29/11/2021 10:38	1h 38m	1h 38m
INCD-310121-U	Mingenew	Emergency Outage For Hazard	30/11/2021 14:38	1h 31m	1h 31m
INCD-311681-U	Perenjori	Unknown	1/12/2021 9:18	3h 54m	3h 54m
INCD-313251-U	Northampton, Yuna	Emergency Outage For Hazard	1/12/2021 19:50	1h 21m	2h 3m
INCD-314651-U	Port Denison, Dongara	Equipment Failure (UG Cable)	2/12/2021 13:08	44m	4d 2h 38m
INCD-315931-U	Mullewa	Unknown	3/12/2021 4:48	31m	31m
INCD-318481-U	Northampton, Horrocks, Nabawa, Gregory, Yuna, Dongara	Unknown	4/12/2021 5:48	1h 34m	1d 16h 27m
INCD-318791-U	Gregory, Northampton	Equipment Failure (Not Entered)	4/12/2021 8:35	11h 19m	1d 4h 1m
INCD-320561-U	Perenjori, Morawa	Unknown	5/12/2021 14:48	1d 6h 12m	1d 6h 12m
INCD-320731-U	Nabawa	Equipment Failure (Not Entered)	5/12/2021 17:22	41m	41m
INCD-320831-U	Perenjori, Morawa	Equipment Failure (Not Entered)	5/12/2021 19:00	1d 2h	1d 2h
INCD-323881-U	Eneabba	Equipment Failure (Not Entered)	7/12/2021 1:40	13h 15m	13h 15m
INCD-323961-U	Northampton	Equipment Failure (OH Conductor)	7/12/2021 2:34	17h 11m	17h 11m
INCD-323951-U	Gregory	Unknown	7/12/2021 2:34	18h 32m	1d 18h 20m
INCD-324241-U	Northampton, Yuna	Equipment Failure (OH Conductor)	7/12/2021 5:47	13h 40m	13h 40m
INCD-20054-X	Perenjori, Morawa	Equipment Failure (Not Entered)	7/12/2021 13:55	1d 6h 1m	1d 6h 1m
INCD-326481-U	Perenjori	Unknown	7/12/2021 14:03	1h 1m	1h 1m
INCD-327201-U	Cervantes	Unknown	7/12/2021 17:03	3h 38m	3h 38m
INCD-327341-U	Cervantes	Vehicle	7/12/2021 17:35	3h 5m	8d 28m
INCD-327751-U	Cervantes	Vehicle	7/12/2021 19:08	1h 12m	1h 12m
INCD-328681-U	Perenjori	Equipment Failure (OH Conductor)	8/12/2021 7:37	12h 23m	12h 45m
INCD-328801-U	Green Head Leeman, Jurien Bay	Equipment Failure (OH Conductor)	8/12/2021 8:22	7h 31m	7h 31m
INCD-333881-U	Three Springs	Lightning	9/12/2021 8:30	4d 22h 8m	4d 22h 8m
INCD-335491-U	Perenjori, Morawa	Unknown	9/12/2021 14:05	2h 36m	16h 14m
INCD-335571-U	Nabawa	Wind or Wind Borne Debris	9/12/2021 14:46	23h 37m	23h 37m
INCD-336851-U	Jurien Bay	Equipment Failure (OH Switch Gear)	9/12/2021 20:47	9h 24m	9h 24m
INCD-340411-U	Perenjori	Unknown	11/12/2021 16:12	2h 8m	2h 8m
INCD-340731-U	Eneabba	Unknown	11/12/2021 20:56	14h	14h
INCD-341431-U	Perenjori	Unknown	12/12/2021 12:57	7m	7m

Incident Reference	Localities impacted	Cause of interruption	Interruption start	Initial restoration	Final restoration
INCD-341461-U	Eneabba	Bird	12/12/2021 13:15	1d 1h 39m	1d 1h 39m
INCD-343591-U	Eneabba	Emergency Outage For Hazard	13/12/2021 13:19	1h 4m	1h 4m
INCD-346001-U	Perenjori	Emergency Outage For Hazard	14/12/2021 14:14	2h 13m	2h 13m
INCD-352771-U	Three Springs	Unknown	17/12/2021 8:38	35m	35m
INCD-352981-U	Eneabba	Equipment Failure (Pole Top Fire, Transformer)	17/12/2021 9:51	6h 39m	6h 39m
INCD-354971-U	Yuna	Equipment Failure (OH Conductor)	20/12/2021 10:27	10h 38m	10h 38m
INCD-356261-U	Perenjori	Unknown	21/12/2021 17:10	2h 29m	2h 29m
INCD-356561-U	Northampton, Yuna	Emergency Outage For Hazard	22/12/2021 7:05	2h 31m	2h 35m
INCD-356891-U	Northampton	Emergency Outage For Hazard	22/12/2021 12:41	2h 36m	2h 36m
INCD-357011-U	Cervantes	Wind or Wind Borne Debris	22/12/2021 16:55	1h 37m	1h 37m
INCD-357381-U	Eneabba	Equipment Failure (OH Conductor, Pole and Structure)	23/12/2021 15:15	4h 9m	4h 9m
INCD-359981-U	Jurien Bay	Equipment Failure (UG Cable)	24/12/2021 19:21	2h 3m	2h 3m
INCD-360801-U	Horrocks	Customer Installation or Appliance	25/12/2021 11:48	2h 28m	2h 28m
INCD-370231-U	Northampton, Horrocks, Nabawa, Gregory, Yuna, Dongara	Unknown	26/12/2021 22:30	19h 39m	1d 13h 3m
INCD-370301-U	Port Denison, Dongara, Mullewa	Unknown	26/12/2021 23:09	32m	21h 34m
INCD-375461-U	Gregory	Unknown	28/12/2021 8:00	6h 7m	6h 7m
INCD-377231-U	Northampton	Customer Installation or Appliance	28/12/2021 19:52	1h 52m	1h 52m
INCD-378571-U	Gregory	Equipment Failure (OH Conductor)	30/12/2021 0:59	11h 40m	17h 59m
INCD-378581-U	Northampton, Horrocks, Nabawa, Yuna, Dongara	Equipment Failure (OH Conductor)	30/12/2021 0:59	10h 29m	11h 23m
INCD-379311-U	Dongara	Emergency Outage For Hazard	30/12/2021 12:50	36m	36m
INCD-379801-U	Mullewa	Equipment Failure (OH Conductor)	31/12/2021 4:22	15h 10m	15h 10m
INCD-379791-U	Eneabba	Equipment Failure (OH Conductor)	31/12/2021 12:10	5h 24m	5h 24m
INCD-380511-U	Dongara	Equipment Failure (OH Switch Gear)	31/12/2021 15:01	3h 30m	3h 30m
INCD-381141-U	Mullewa	Equipment Failure (Pole Top Fire)	1/01/2022 9:04	32m	32m
INCD-381851-U	Green Head	Customer Installation or Appliance	2/01/2022 11:30	5h 2m	5h 2m
INCD-382601-U	Morawa	Equipment Failure (OH Conductor, OH Switch Gear)	3/01/2022 11:25	9d 2h 19m	9d 2h 19m
INCD-384381-U	Port Denison, Dongara	Unknown	5/01/2022 3:44	48m	4h 26m
INCD-384391-U	Northampton, Horrocks, Nabawa, Gregory, Yuna, Dongara	Wind or Wind Borne Debris	5/01/2022 4:49	6h 30m	14h 30m
INCD-384751-U	Nabawa	Unknown	5/01/2022 12:04	3h 42m	3h 42m
INCD-384841-U	Northampton	Unknown	5/01/2022 14:21	3h 38m	3h 38m
INCD-385211-U	Gregory	Unknown	5/01/2022 21:30	11h 49m	11h 49m
INCD-386281-U	Mullewa	Equipment Failure (Pole Top Fire)	7/01/2022 8:05	34m	1d 8h 6m
INCD-386951-U	Jurien Bay	Unknown	7/01/2022 17:48	15h 31m	15h 31m
INCD-388161-U	Mullewa	Unknown	9/01/2022 3:14	32m	32m
INCD-388821-U	Mullewa	Customer Installation or Appliance	10/01/2022 6:22	5h 51m	5h 51m
INCD-390021-U	Eneabba	Equipment Failure (Pole Structure)	11/01/2022 10:39	9h 14m	7d 5h 4m
INCD-390491-U	Gregory, Northampton	Emergency Outage For Hazard	11/01/2022 23:44	57m	8h 37m
INCD-392431-U	Northampton	Emergency Outage For Hazard	14/01/2022 8:38	3h 12m	3h 12m
INCD-392581-U	Nabawa	Equipment Failure (Service Connection)	14/01/2022 9:43	1h 25m	1h 25m
INCD-394181-U	Jurien Bay	Equipment Failure (Not Entered)	16/01/2022 20:09	12h 56m	12h 56m
INCD-395231-U	Gregory	Equipment Failure (OH Conductor)	18/01/2022 3:57	6h 22m	6h 22m
INCD-395241-U	Horrocks, Northampton, Dongara	Equipment Failure (OH Conductor)	18/01/2022 3:57	7h	10h 22m
INCD-395351-U	Eneabba	Equipment Failure (Not Entered)	18/01/2022 8:37	1h 22m	7h 6m
INCD-396901-U	Jurien Bay	Emergency Outage For Hazard	18/01/2022 19:31	32m	32m
INCD-396661-U	Northampton	Equipment Failure (OH Conductor)	19/01/2022 11:00	58m	58m
INCD-405091-U	Port Denison, Dongara, Mullewa	Equipment Failure (OH Conductor, Transformer)	23/01/2022 7:20	9h 58m	1d 10h 4m
INCD-405901-U	Mullewa	Emergency Outage For Hazard	23/01/2022 20:36	1 hour	20h 9m
INCD-406101-U	Mullewa	Emergency Outage For Hazard	24/01/2022 4:12	5h 50m	11h 41m
INCD-406701-U	Mullewa	Emergency Outage For Hazard	24/01/2022 16:26	48m	2h 49m

Incident Reference	Localities impacted	Cause of interruption	Interruption start	Initial restoration	Final restoration
INCD-406801-U	Northampton	Emergency Outage For Hazard	24/01/2022 17:40	12m	23h 6m
INCD-406951-U	Northampton	Emergency Outage For Hazard	24/01/2022 19:16	9m	21h 30m
INCD-408021-U	Dongara	Emergency Outage For Hazard	25/01/2022 14:53	1h 19m	1h 19m
INCD-409121-U	Horrocks, Gregory, Northampton, Dongara	Customer Installation or Appliance	26/01/2022 7:35	12h 33m	12h 33m
INCD-409921-U	Perenjori	Bird	27/01/2022 7:16	1h 57m	1h 57m
INCD-410591-U	Mingenew	Unknown	27/01/2022 14:41	4h 57m	4h 57m
INCD-411101-U	Horrocks, Dongara	Vegetation	28/01/2022 6:56	11h 50m	11h 50m
INCD-12475-Y	Jurien Bay	Equipment Failure (Not Entered)	28/01/2022 10:41	1h 11m	1h 11m
INCD-411501-U	Mullewa	Wind or Wind Borne Debris	28/01/2022 17:11	15h 19m	3d 21h 44m
INCD-411541-U	Yuna	Emergency Outage For Hazard	28/01/2022 17:43	24m	2h 19m
INCD-411801-U	Horrocks, Gregory, Northampton, Dongara	Equipment Failure (Not Entered)	29/01/2022 3:52	9h 9m	15h 37m
INCD-411571-U	Mullewa	Unknown	29/01/2022 6:56	1d 14h 2m	1d 14h 2m
INCD-413801-U	Gregory, Northampton	Unknown	30/01/2022 0:44	7h 2m	7h 2m
INCD-414561-U	Three Springs	Emergency Outage For Hazard	30/01/2022 10:03	3m	7h 2m
INCD-415181-U	Perenjori	Unknown	30/01/2022 19:44	3h 25m	3h 25m
INCD-415351-U	Horrocks, Dongara	Unknown	31/01/2022 1:42	12h 29m	17h 32m
INCD-415511-U	Green Head Leeman, Jurien Bay	Unknown	31/01/2022 6:29	12h 11m	12h 11m
INCD-415551-U	Jurien Bay	Equipment Failure (Not Entered)	31/01/2022 7:46	3h 17m	3h 17m
INCD-415621-U	Nabawa, Northampton	Emergency Outage For Hazard	31/01/2022 8:43	1h 35m	8h 39m
INCD-416101-U	Dongara	Bird	31/01/2022 16:13	3h 38m	3h 38m
INCD-416611-U	Northampton	Equipment Failure (Not Entered)	31/01/2022 23:18	32m	32m
INCD-416771-U	Perenjori	Unknown	1/02/2022 7:02	4h 54m	6h 6m
INCD-418991-U	Three Springs	Unknown	2/02/2022 14:47	34m	34m
INCD-419101-U	Cervantes	-	2/02/2022 16:17	34m	34m
INCD-419481-U	Dongara	Emergency Outage For Hazard	2/02/2022 23:18	4m	4m
INCD-420111-U	Horrocks	Customer Installation or Appliance	3/02/2022 15:37	3h 44m	3h 44m
INCD-421221-U	Mullewa	Emergency Outage For Hazard	4/02/2022 9:31	1h 34m	1h 34m
INCD-421321-U	Horrocks	Emergency Outage For Hazard	4/02/2022 10:31	6h 51m	6h 51m
INCD-422731-U	Horrocks	Emergency Outage For Hazard	5/02/2022 10:31	6h 16m	6h 18m
INCD-423591-U	Port Denison, Dongara	Emergency Outage For Hazard	5/02/2022 21:56	33m	20h 10m
INCD-425781-U	Port Denison, Dongara, Mullewa	Transmission Failure	5/02/2022 21:58	19h 15m	19h 15m
INCD-423721-U	Dongara, Port Denison, Mullewa	Unknown	5/02/2022 22:31	5m	5m
INCD-423811-U	Gregory	Emergency Outage For Hazard	6/02/2022 1:26	21h 57m	1d 14h 38m
INCD-423831-U	Jurien Bay	Equipment Failure (OH Switch Gear)	6/02/2022 1:47	3h 34m	13h 32m
INCD-423911-U	Green Head Leeman, Jurien Bay	Equipment Failure (Not Entered)	6/02/2022 2:53	6h 37m	15h 8m
INCD-423981-U	Northampton, Nabawa, Yuna, Horrocks	Unknown	6/02/2022 5:39	15h 46m	1d 13h 35m
INCD-424061-U	Northampton	Unknown	6/02/2022 6:49	1d 12h	2d 5h 6m
INCD-27215-Y	Northampton	-	6/02/2022 6:55	2h 54m	2h 54m
INCD-425071-U	Mullewa, Nabawa, Northampton	Transmission Failure	6/02/2022 8:45	1h 54m	2h 58m
INCD-425671-U	Perenjori	Unknown	6/02/2022 11:17	10h 20m	10h 20m
INCD-425721-U	Morawa	Unknown	6/02/2022 11:25	8h 29m	8h 29m
INCD-425771-U	Port Denison, Dongara, Mullewa	Transmission Failure	6/02/2022 12:05	3h 45m	3h 45m
INCD-427401-U	Green Head Leeman, Jurien Bay	Equipment Failure (Pole Top Fire)	6/02/2022 19:13	17h 17m	17h 17m
INCD-427531-U	Eneabba	Emergency Outage For Hazard	6/02/2022 19:54	5h 47m	21h 20m
INCD-430021-U	Eneabba	Emergency Outage For Hazard	7/02/2022 11:54	2h 20m	2h 20m
INCD-429831-U	Eneabba	Emergency Outage For Hazard	7/02/2022 13:54	54m	1h 23m
INCD-431041-U	Horrocks	Emergency Outage For Hazard	8/02/2022 7:27	9h 22m	9h 22m
INCD-431281-U	Eneabba	Emergency Outage For Hazard	8/02/2022 9:26	1h 39m	1h 41m
INCD-432301-U	Nabawa	Unknown	9/02/2022 8:20	4h 30m	4h 30m

Incident Reference	Localities impacted	Cause of interruption	Interruption start	Initial restoration	Final restoration
INCD-432381-U	Horrocks	Emergency Outage For Hazard	9/02/2022 9:11	3h 39m	3h 39m
INCD-432561-U	Gregory	Emergency Outage For Hazard	9/02/2022 11:32	2h 16m	2h 17m
INCD-432901-U	Horrocks, Dongara	Emergency Outage For Hazard	9/02/2022 16:23	5m	5m
INCD-432921-U	Horrocks	Emergency Outage For Hazard	9/02/2022 16:33	3m	3m
INCD-432941-U	Horrocks	Emergency Outage For Hazard	9/02/2022 16:46	2m	2m
INCD-432971-U	Horrocks	Emergency Outage For Hazard	9/02/2022 17:40	2m	2m
INCD-433901-U	Eneabba	Equipment Failure (Pole Top Fire)	10/02/2022 10:55	4h 31m	4h 31m
INCD-433991-U	Northampton	Emergency Outage For Hazard	10/02/2022 11:44	1h 5m	1h 5m
INCD-434641-U	Gregory	Unknown	10/02/2022 21:27	14h 34m	14h 35m
INCD-434701-U	Northampton	Customer Installation or Appliance	11/02/2022 1:29	10h 29m	13h 56m
INCD-435931-U	Perenjori	Lightning	11/02/2022 17:03	1h 41m	1h 41m
INCD-436431-U	Northampton	Unknown	12/02/2022 2:47	33m	33m
INCD-436481-U	Northampton	Unknown	12/02/2022 4:50	2h 45m	1d 20h 5m
INCD-437621-U	Northampton, Mullewa, Horrocks, Nabawa, Yuna, Dongara	Emergency Outage For Hazard	13/02/2022 1:06	20m	21m
INCD-437821-U	Nabawa	Emergency Outage For Hazard	13/02/2022 8:43	6m	6m
INCD-438451-U	Perenjori, Morawa	Equipment Failure (OH Conductor)	13/02/2022 19:22	3h 12m	15h 56m
INCD-438441-U	Morawa	Lightning	13/02/2022 19:56	4m	4m
INCD-438431-U	Perenjori	Equipment Failure (Not Entered)	13/02/2022 23:06	13m	13m
INCD-439151-U	Perenjori	Equipment Failure (Not Entered)	14/02/2022 11:24	2m	2m
INCD-440401-U	Perenjori	Unknown	14/02/2022 16:47	49m	49m
INCD-440421-U	Perenjori, Morawa	Unknown	14/02/2022 16:49	44m	44m
INCD-440741-U	Mullewa	Lightning	14/02/2022 17:06	1d 9m	1d 9m
INCD-441321-U	Morawa	Unknown	14/02/2022 18:46	1h 7m	1h 7m
INCD-441621-U	Morawa	Lightning	14/02/2022 19:49	16h 33m	16h 33m
INCD-442021-U	Perenjori	Emergency Outage For Hazard	14/02/2022 21:47	31m	31m
INCD-442171-U	Gregory, Northampton	Equipment Failure (Not Entered)	15/02/2022 2:16	35m	1d 14h 13m
INCD-441121-U	Yuna	Lightning	15/02/2022 9:15	12m	6h 33m
INCD-444301-U	Morawa	Unknown	16/02/2022 7:36	4h 49m	4h 49m
INCD-445361-U	Mullewa	Bird	16/02/2022 12:24	5h 23m	5h 23m
INCD-451351-U	Port Denison	Emergency Outage For Hazard	20/02/2022 9:03	2h 24m	2h 24m
INCD-451941-U	Perenjori, Morawa	Equipment Failure (UG Cable)	20/02/2022 19:27	45m	18h 38m
INCD-452171-U	Port Denison, Dongara, Mullewa	Equipment Failure (Not Entered)	21/02/2022 1:11	4h	14h 42m
INCD-452181-U	Horrocks, Northampton, Dongara, Gregory	Unknown	21/02/2022 3:39	14h 24m	14h 38m
INCD-452351-U	Northampton	Unknown	21/02/2022 8:40	23m	9h 31m
INCD-453321-U	Northampton	Unknown	22/02/2022 7:17	11h 45m	11h 45m
INCD-453711-U	Perenjori	Unknown	22/02/2022 7:50	6h 7m	6h 7m
INCD-453631-U	Gregory	Emergency Outage For Hazard	22/02/2022 10:55	5h	5h
INCD-454171-U	Northampton	Unknown	22/02/2022 19:25	1h 48m	1h 48m